

Addendum No. 2

Owner: City of Unalaska

Project: **PYRAMID WTP MICROTURBINE PROJECT**
DPW Project No. 17401

Date: **May 21, 2019**

Please acknowledge receipt of this Addendum in the appropriate blanks on the bid form. The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the contract documents for the subject project. In case of conflicts between this Addendum and previously issued documents, this Addendum shall take precedence.

Item 1

Reference Unalaska Pyramid WTP Microturbine Project BID DOCUMENTS TECHNICAL SPECIFICATIONS

Specification '**22 11 13 – FACILITY WATER DISTRIBUTION PIPING**'

REVISE Section 1.4, A, 3 to say:

3. FITTINGS 10" NPS and smaller – Stainless steel, Grooved Ends, Schedule 40 Bore, AWWA C-606 and ASTM F-1476, with gaskets per ASTM D-2000

Victualic style grooved end fittings shall not be allowed for pipe larger than 10" NPS.

Item 2

Reference Unalaska Pyramid WTP Microturbine Project BID DOCUMENTS TECHNICAL SPECIFICATIONS

Specification '**22 11 13 – FACILITY WATER DISTRIBUTION PIPING**'

REVISE Section 1.4, A, 5 to say:

5. When dissimilar metals are joined with flanges, non-metallic bolt isolation kits shall be used to prevent electrical current through the stainless-steel stud bolts.

NSF 61 certified gaskets shall be used throughout the facility. Bolt isolation kits are to be used to isolate all dissimilar metals when flanged.

End of Addendum No. 2

Attachments

None