

Addendum No. 4

Owner: City of Unalaska

Project: **LIBRARY EXPANSION PROJECT**
DPW Project No. 15105

Date: **November 16, 2021**

Please acknowledge receipt of this Addendum in the appropriate blanks on the bid form. The following corrections, changes, additions, deletions, revisions, and/or clarifications are hereby made a part of the contract documents for the subject project. In case of conflicts between this Addendum and previously issued documents, this Addendum shall take precedence.

Item 1

Question: In the Metal Roofing specification a wind speed warranty rider was not called out. Specification Section 07 4113 1.07 A-C. calls out a 20 year material finish warranty and 20 watertight warranty. Will a wind speed warranty rider be requested? If yes, please note that 120 MPH wind speed warranty is the maximum offered.

Response: Provide 20-year roof warranty for 120 MPH wind speed.

Item 2

Question: Please clarify what doors get access control and card readers. Some information is not matching the hardware spec and the electrical drawings.

Response. Provide power for a single card reader at the following doors 101A, 101B, 140 and e110. Please remove all other references to additional card readers. Note hardware sets for doors 101A and 101B only need one card reader, not two.

No attachments

The bid date remains unchanged

End of Addendum No. 4