



## Sustainable and Affordable





- Accomplished:
  - Assembled a top-notch technical team
  - Findings: larger load commitment equates to a larger power plant and lowers consumer costs
  - However, in the future power plant can be expanded
- · Why OCCP?
  - Non-recourse loan
  - · Ounalashka Corp owns lease, is project lead
  - New, proven innovative technology

### We've done this before We can do it again! Chena Hot Springs Resort (An isolated 2,000-acre property) (An isolated 7,000-acre property) 10 Miles of Road 20 Miles of Road 3-4 Bridges 4 Bridges 20 Miles of Pipeline 10 Miles of Pipeline 12,200 Ft. of Wells Drilled 16,000 Ft. of Wells to drill 115,000 Sq. Ft. of Buildings Heated > 1 M Sq. Ft. of Buildings Heated 11,400 Sq. Ft. of Greenhouses Acre of Greenhouses Hot Springs Hot Springs \* water utility in Unalaska not considered







Prosperity



ST-1 well test looking from the north. Camp is visible in the distance to the south by exploration well E-1


ffrom: Development Potential of the Masunhin Geothermal Reservoir of Unalaska Island, David Berlig-Chakroff, John W. Reeder, and Michael J. Economides: CRC Transactions, Vol 9:Part 1, August 1985.

- In 1981 the Alaska Power Authority (APA), contracted with Republic Geothermal, Inc. to explore the vicinity of Makushin Volcano for geothermal resources.\*
- Stratigraphic Test Well No. 1 (ST-1) was spudded on July 2, 1983\*
- A production well should be capable of flow rates of 1.25 to 2 million lb/hr at a wellhead pressure of 60 psia.\*
- The reservoir appears likely to be confined to an approximately two-mile-wide zone trending northeast from Glacier Valley to Driftwood Bay valley.\*

## MGP Initial Development Decision Tree







All decisions are linked to future decisions in a logical manner called a decision tree

Before Project Sanctioning (loan is approved), several project tasks need to be completed

## Project Plan





- A road will be built from Broad Bay to the plant.
- A geothermal power plant will be installed near discovery well ST-1 sufficient to meet Unalaska's electrical and heating needs.
- Other production and injection wells drilled in the vicinity.
- Power plant technology is new, innovative and very efficient.
- Power transmission and fiber optic communications lines will be installed
- Transformer station will link to Unalaska's grid.
- Option Residential and industrial and commercial heat pumps will be supplied and installed to replace existing diesel systems.





# Project Plan and Schedule







Task	Duration	Start	Finish
Power Purchase Agreement with Unalaska	110	12/12/19	3/31/20
DOE Phase 1 application process	342	4/3/19	5/5/20
Summer 2020 engineering definition work	76	6/1/20	8/15/20
Permitting and environmental work	313	12/16/19	12/14/20
DOE Phase 2 application process	153	5/7/20	10/31/20
2021 Summer Season work	120	4/1/21	8/18/21
Equipment Procurement	125	9/9/21	2/21/22
Equipment Manufacturing	365	5/18/21	7/16/22
Shipping and Transport	40	3/29/22	5/13/22
2022 Work Season work	148	5/11/22	10/29/22
Commissioning and verification testing	120	7/6/22	11/22/22
Commercial Operation	1	12/14/22	12/14/22


Total Project Duration 3.6 years


Three mobilizations in '20,'21, and '22


Project major tasks include planning, permitting, PPA acquisition, engineering, drilling, construction and commissioning












## NEPA Process for MGP Launched OCCP has initiated actions with DOE starting NEPA process for MGP A request for approval from DOE of our 2020 environmental work activities in order to initiate meaningful evaluation of potential environment affects of MGP A summary will be prepared to address environmental impact categories identified in DOE code of federal regulations • Discussion with Agencies will begin (ADF&G, USFG&WS, BLM, NOAA EPA, DEC), with federal recognized Alaska Native Tribes, and other interested parties Meetings will be held with affected parties for their comments and level of support • Evidence and analysis will be prepared to determine if EIS, EA, or no significant impact findings are appropriate Your participation and support is requested

# Project Costs and Energy Take-Off Energy Sales (\$/kWh) vs. Energy Off-take (MkWh) \*\*Output Ashka\*\* \*\*Prospective\*\* \*\*All six options are plotted illustrating the relationship between energy sales price and energy off-take. \*\*Dural Ashka\*\* \*\*Check\*\* \*\*All six options are plotted illustrating the relationship between energy sales price and energy off-take. \*\*Check\*\* \*\*Check\*\* \*\*Check\*\* \*\*Check\*\* \*\*All six options are plotted illustrating the relationship between energy sales price and energy off-take commitments decrease energy sales price.




## What Are Air Source Heat Pumps?








An air source heat pump (ASHP) works by harvesting heat energy from the air and push that energy into your home, even when it's below zero there's still heat in the air.\*





An ASHP effectively extracts heat from the cold outdoors, concentrates it, and delivers it inside to keep you warm all winter. According to the laws of physics, a lot less energy is required to move heat than

- ASHPs heat a home at efficiencies of well over 100% in cool weather.
- For comparison, conventional heating systems that run on gas, oil, or propane have efficiencies between 80-97%.
- But when the heat pump efficiency is calculated, the useful heat delivered is much larger than the energy you buy at the meter.
- In a cold climate, the average efficiency for an entire winter is typically in the 200-250%.
- That translates to dollars saved!\*

From Northeast Energy Efficiency Partnerships (HEEP). Air Source Heat Pump Buying Guide

## ASHPs Meet All Your Heating Needs





ASHPs can meet all your home's heating needs no matter what your current's systems configuration

ASHP Myth #1: Heat pumps don't work below freezing

ASHP Fact: Today's coldclimate units have enhanced heating capacity in cold weather and should be left running under all outdoor conditions.\*



**ASHP Myth #2**: Heat pumps are expensive to operate.

ASHP Fact: Most cold climate heat pumps have high heat output and don't even have electric backup heaters.\*







Ducted and ductless ASHPs can be customdesigned, mixed, and matched to meet your home's heating and cooling needs.

ASHPs can heat water to power hydronic floorboard systems and meet your domestic hot water needs too.

ASHPs can heat individual rooms, be configured to your work with your forced-air system.

From Northeast Energy Efficiency Partnerships (NEEP). Air Source Heat Pump Buying Guide


## Sustainable and Affordable







- Accomplished:
  - Assembled a top-notch technical team
  - Findings: larger load commitment equates to a larger power plant and lowers consumer costs
  - However, in the future power plant can be expanded
- Why OCCP?
  - Non-recourse loan
  - Ounalashka Corp owns lease, is project lead
  - New, proven innovative technology


































# To help build a self-sustaining and prosperous community Unalaska has: • Energy source • Delivered • Food security • Cheaper energy, and • Economic prosperity











### PPA Offer Summary OUNALASHKA Off-Take energy Net (MWe) ranges from 53 to Sase Case, Plant 18MWs, Load SMWs CITY CASE with out Heat pump 138 MkWh 18.4 53.0 Energy sales prices Base Case + (Alyeska + Westward 1.9MWe) loads range from 13 to 20 8.2 71.8 \$0,19 1,9MWe) loads 23 cents/kWh 16 MW plant with 15 MW BESS 18.4 \$0.19 8.2 71.6 22 24.4 24 11,8 103.6 \$0.15 CITY CASE with HEAT PUMP Base Case, Plant 18MWs, Load 6MWs + Heat Pump load, plus 15 MW BESs • A total of 11 options have been 4.0 17 21 87.7 \$0,16 developed to accommodate the Base Case, Plant 22.4MWe, Loed 6MWe + Heat Pump load, Plus 15 City's complex needs 21 87.7 \$0.18 Power plant nameplate ranges 12.1 108.3 \$0.14 from 18 to 30MWe 121 • A 15MW battery is also an option in some cases to handle peak loads sse Caso 26.4 MW + (Alyeska + lestward + 1.9MWe) loads + Host 4.0 24 12.1 60,15 108.3 • Five options have an air source iane Case • UniSoa • (Alyeska • Vestward • 1.9MWe) loads + Heat tump load, Plus 15 MW BESS heat pump project added 16.8 138.3 \$0.13

